


JEFFERSON COUNTY

Community Development Department

85 SE "D" Street • Madras, Oregon 97741 • Ph: (541) 475-4462 • Fax: (541) 325-5004



INSPECTION REQUEST

Job Address: [REDACTED]

Type of Inspection: ELE. SERVICE / ROUGH PLUMBING
ROUGH MECH.

☒ Electrical ☒ Plumbing ☒ Structural ☒ Mechanical ☐ Manufactured Home

Permit No. [REDACTED]

Owner: [REDACTED]

Contractor: BRIAN WOOD

541-480-4136

INSPECTION REPORT

Date inspected: 4-24-13 Time: _____

Type of Inspection: _____

☐ Unable to inspect ☐ No corrections noted ☐ Correction(s) expected within _____ days.

Inspection Report No.: _____ ☐ Correction(s) noted: (Page _____ of _____).

① 4" FLEX NOT CODE COMPLIANT FOR
80 CFM FAN. R1507 ORSC

TOP OUT PLUMBING

IRON MAN PLUMBING
JESSIE MOOR

ROUGH ELE

APPROVED

FRAMING APPROVED

☒ Reinspection required prior to approval / call to reschedule

ON MECHANICAL

Inspector Name: _____

[Signature]