



Geotechnical & Construction Services

File Only
Daily Field Inspection Report

Project Name:

Date:

8/27/12

Project Number:

Weather:

Clear

Client:

Permit Number:

Inspection of:

Continuous ☐

Periodic ☒

Contractor:

Comments:

Inspected footing excavations for 3000 psf foundation loads. All areas exposed the material specified in our report dated April 3, 2012. The excavation and preparation of these areas is acceptable and in conformance with our recommendations.

TO THE BEST OF OUR KNOWLEDGE, THE WORK INSPECTED WAS IN ACCORDANCE WITH

report

AND APPLICABLE WORKMANSHIP PROVISIONS OF THE IBC, EXCEPT IF NOTED ABOVE.

SIGNED:

William A Smith

I.D. NUMBER:

FE15779

PRINT FULL NAME:

William A Smith

REVIEWED BY:

REPORT SUBJECT TO CHANGE PRIOR TO FINAL ISSUANCE SHOULD ADDITIONAL INFORMATION BECOME AVAILABLE.

This report and/or enclosed test data is the confidential property of the client to whom it is addressed and pertains to the specific process and/or material evaluated. As such, information contained herein shall not be reproduced in part or full and/or any part thereof be disclosed without FEI Testing & Inspection, Inc.'s written authorization.